





Advanced Cogeneration Technologies to Reduce SAGD GHG Emissions

Presented at New Technologies for In Situ Oil Sands Facilities 2017 May 30th in Calgary

Song P. Sit¹ and David Layzell – CESAR/University of Calgary Viola Birss, Kunal Karen and Jason Young – CAESR-Tech/University of Calgary

¹ University of Calgary, Biological Sciences 578, 2500 University Drive NW, Calgary, AB T2N 1N4, 403-210-9668 or song.sit@ucalgary.ca







<u>Outline</u>

- 1. Introduction to CESAR and CAESR-Tech
- 2. SAGD with Conventional Cogeneration per CESAR Study
- 3. Advanced Cogeneration Technologies
 - 1. Molten Carbonate Fuel Cells
 - 2. Solid Oxide Fuel Cells
- 4. CASER-Tech SOFC improvements
- 5. Conclusions and Next Steps







CESAR (Canada Energy Systems Analysis Research) is an initiative that was started at the University of Calgary in 2013 to understand and inform energy systems change in Canada. By building data resources and visualization tools, analyzing past and present energy systems and modeling energy futures, CESAR researchers work to inform policy and investment decisions regarding the transformation of Canada's energy systems towards sustainability. <u>http://www.cesarnet.ca/</u>

CAESR-Tech is a University of Calgary research center for research, training and innovation in next generation electrochemical energy storage/ conversion technologies. Our Mission is to develop advanced electrochemical technologies to achieve significantly lower or zero GHG emissions in the utilization of fuel resources in close collaboration with the energy/environment sector in Canada. http://www.ucalgary.ca/caesr/

OSF2017 May 30







Conventional SAGD

- Deploys OTSG to make steam and imports electricity from AB Grid
- Emission intensity @ 75 kg CO₂ per bbl is 3X conventional crude
- High intensity undermines public support for continued development
- AB Bill 25 limits total oil sands annual GHG emissions to 100 Mt
- Encourages cogeneration to reduce emission intensity











Conventional SAGD Cogen

- Conventional Cogen deploys GT to produce electricity and HRSG to make steam, as compared with conventional OTSG and power import
- CESAR extensively modeled multiple cases of deploying Cogen in a typical 33 kBPD SAGD project at SOR of 2 to 4
- In all cases, Cogen improves SAGD energy efficiency & reduces emission intensity

http://www.cesarnet.ca/sites/default/files/CESAR-Scenarios-SAGD-Cogeneration-Reducing-Carbon-Footprint-Oil%20Sands-Grid.pdf







CESAR SAGD Cogeneration Evaluation Cases

Case Studies	SAGD Heat	SAGD Power	Power to Grid
1. Base Case	OTSG	From Grid	No
2. One Cogen unit* @ 100% load factor	~50% OTSG ~50% Cogeneration	From SAGD Cogen	Yes
3. Two Cogen units* @ 100% load factor	Cogeneration		
4. Two Cogen units* @ 60% load factor (space for renewable backup)			

* A cogen unit consists of an 85 MW_e gas turbine (GT), coupled to a heat recovery steam generator (HRSG) that can receive additional fuel (duct burning, DB), or addition fuel plus combustion air (forced air duct burning, FA-DB).
 OSF2017 May 30
 Song P. Sit, PhD, P.Eng. CESAR







A Systems Level Perspective Two 85 MW_e GT (100% Load) on Equivalent Crude & Grid Power Output 33kb/d SAGD Facility without Cogeneration kt CO₂/d kt CO₂/d **Duct Burning** 15.9 TJ/d PROD'N (P/IL 2 33.4 TJ/d OTSG CRUDE 5.0' w 17.5 TJ/d TJ/d Useable -:TUQN ռնանականականունունուն Heat OTAL ENERGY INPUT: 80. С 1.2 TJ/d Turbines@ 49. 1.5 TJ/d TOTAL ENERGY Power GRID Generation (13.5 Public Grid (b/LT Power Gen. 31.1 TJ/d Gas Losses 2-່ຫ 17.5 1.8 9.2 23.0 b/LT b/LT tJ/d TJ/d TOTAL LOSSES: TOTAL LOSSES: (32.2 TJ/d; 39.9% of energy input) (19.2 TJ/d; 28.5% of energy input)

Sankey Comparison

- Cogen thermal efficiency is 71.5%, 20% higher
- H/P = 2.3
- Exports 152 MW of low GHG intensity power (deemed 390 kg/MWh) vis-à-vis Grid intensity of 790 kg/MWh (2015)
- SAGD emission intensity reduced to 60 kg/bbl at SOR of 3, 25% reduction

OSF2017 May 30



SAGD Intensity with Cogen

- All Cogen Cases have lower GHG emissions per barrel than the base (no Cogen) case
- These emissions are still much higher than those associated with conventional oil
- Deploying two 85 MW running at 60% Load Factor could provide backup to renewables when ramping up to 100% LF
- Cogen is a transitional step to more advanced technologies

8







Fuel Cells are Advanced Cogen Technologies for SAGD









- Fuel cells could replace conventional Cogen of GT + HRSG
- Advanced electrochemical technologies suited for SAGD:
 - Molten carbonate fuel cells (MCFC)
 - Solid oxide fuel cells (SOFC)
- MCFCs concentrate CO₂ from steam boilers at lower avoidance cost vis-à-vis conventional PCC with amine, while exporting a modest amount of power, and CO₂ must be disposed of
- SOFCs produce steam and export power, and produced CO₂ is capture ready, i.e., CO₂ produced at high concentration, *either* emitted, *or* purified to EOR or storage specifications *later*









- AIEES and 5 oil sands producers in 2013 jointly funded a study to evaluate deploying these 2 types of fuel cells in SAGD (2013 Study)
- Base Case conventional 33 kBPD SAGD at SOR of 3 using OTSG and importing power
- Install 76 MW MCFC, remove CO₂ from OTSG for storage, export modest amount of power (48 MW/33 kBPD), and compared with conventional SAGD with post combustion CCS using amine
- Install 1,100 MW SOFC, export prolific amount of power (960 MW/33 kBPD), steam recovered from exhaust gases for SAGD (H/P = 0.4), and compared with SAGD conv. Cogen, with or w/o CCS

http://www.canadiancleanpowercoalition.com/files/4214/3018/3638/CCS29 -_ecm_evaluation_study_report-final_all.pdf







Key Study Results of MCFC with CCS

30

OTSG

ECM



Avoidance Cost

Fuel Cell Replacements

Capex

Transmission

- Fixed and Variable O&M
- Power Purchases
- Fuel Costs
- Power Sales

MCFC is aka ECM (electrochemical membrane) in the Study







Key Study Results of SOFC <u>without</u> CCS



Note: 2014 Grid GHG intensity was 762 kg/MWh. All numbers shown above were extracted from the ECM Evaluation Report, Jacobs Consultancy, 2013. CESAR's Study has shown that OTSG's total GHG intensity is higher at 75 kg per barrel of which 10 kg per barrel is indirect.







- The SOFC heat/power (H/P) ratio in the Study is 0.4, ~ 20% conv.
 Cogen and not attractive for SAGD
- CAESR-Tech carried out comprehensive simulations of implementing SOFC in SAGD
- Incorporated latest CAESR-Tech SOFC advancement and learnings in order to address the low H/P ratio
- Motivations are:
 - Increase SOFC's H/P ratio while keeping SOFC's high efficiency
 - Show potential SOFC capital cost reduction







Lower SOFC Capital Cost at Higher Current Density









SOFC are CO₂ Capture Ready (no PCC with Amine)



- SOFC anode exhaust contains high CO₂ concentration, and low residual CH₄, CO & H₂
- Achieved at utilization efficiency > 80%
- Liquid CO₂ and residual fuels recoverable via purification
- CO₂ meets EOR spec
- Residual fuel recycled to achieve ~ 100% utilization







CAESR-Tech SAGD SOFC Process Simulation



OSF2017 May 30







SOFC are Tunable to Output Different H/P ratio









CAESR-Tech SAGD SOFC Results – H/P 个 0.8 <u>w/o</u> CCS

Higher Heat Output reduced Power Output



Note: 2014 Grid GHG intensity was 762 kg/MWh. All numbers shown above were extracted from the ECM Evaluation Report, Jacobs Consultancy, 2013. CESAR's Study has shown that OTSG's total GHG intensity is higher at 75 kg per barrel of which 10 kg per barrel is indirect.

OSF2017 May 30

Song P. Sit, PhD, P.Eng. CESAR







Conclusions

- Cogeneration reduces SAGD emissions, allowing continued oil sands expansions under Bill 25's 100 Mt cap
- Conventional Cogen provides modest GHG reduction and a transition step to commercialize advanced Cogen technologies such as fuel cells
- MCFC and SOFC are both capable of Cogen and CCS
- SOFC is more attractive:
 - Highly efficient and CO₂ capture ready, not tied to PCC per se, as CO₂ purification to EOR or storage specs. can be retrofitted later
 - Operationally tunable, increasing H/P to 0.8, ~ 2 times 2013 Study
 - Potential to significantly reduce their capital costs







SOFC Next Steps

- Optimize H/P tuning for new SAGD production technologies, e.g., evaporators, SAP or ESEIEH, to find the most suitable H/P and current density (*i*) at the best fuel utilization (η_{Total}) for each
- Validate the optimization in collaboration with SOFC vendors and oil sands producers
- Scale up SOFC for SAGD:
 - 5 to10 kW pilot
 - Scale up in MW demo







Acknowledgements

CESAR SAGD Cogen Study Supporters

- Edmonton Community Foundation
- Candor Engineering
- Alberta Innovates Energy Environment Solutions, Cenovus, MEG Energy, Nexen Energy ULC, Suncor Energy and Anonymous Co.

SOFC Study

- CAESR-Tech
- NSERC
- Dr. Scott Paulson
- Fuel Cell Energy